



STORM WATER BMP (Best Management Practices) INSPECTION REQUIREMENTS

****Permits are required prior to beginning any work****

Less than 1 acre
(CPPJ Permit Only)

1 to less than 5 acres
(DEQ Permit Compliance--Notice of Termination)

5 acres or more
(DEQ Permit Application--Notice of Intent & Termination)

Storm Water Initial Inspection: (call w/ permit # when all measures are installed & in place)

1. [Silt fencing](#) / [filter logs](#), when necessary, around perimeter of grading site installed properly
2. [Storm drain/catch basins](#) protected from debris and runoff using silt fencing/hay bales, etc...
3. [Temporary driveway](#) entrances constructed to minimize tracking of sediments onto roadway

Storm Water Interim Inspection/s: (performed as necessary during the construction process)

1. Performed to check on maintenance & integrity of installed protective measures
2. Performed to check discharge points (catch basins, storm drains, etc...)
3. Performed to check for pollution prevention/good housekeeping practices ([debris/waste](#) is properly contained, proper [material storage](#)/disposal, proper [washouts for paint/concrete](#), proper [sanitary waste disposal](#), proper [dust control](#), proper [soil stockpiling and topsoil preservation](#), etc...)

Storm Water Final Inspection: (performed when site has been stabilized (using any of or combination of these measures, 70% density cover—see below)

1. Performed when temporary/permanent [seeding](#) or [sod](#) has been installed
2. Vegetative buffer strips in place
3. Landscaping
4. All construction debris and trash have been removed from site

****Failure to call for Initial Storm Water BMP inspection may result in the withholding of building permits and/or building inspections. Disapprovals of on-site inspections may result in stop work orders and/or written notice of violation.**

****Approved Grading Plan and Storm Water Pollution Prevention Plan (SWPPP), if applicable shall be posted in a conspicuous location on the construction site. Failure to adhere to the regulations set forth in the [Calcasieu Parish Storm Water Ordinance #6143](#) shall result in [Civil Penalties](#) being assessed.**

SIGNATURE

DATE